FLASHING AND SHEET METAL SCHEDULE

	MIL FIN ALUM	PTD ALUM (FLOURO-CARB)	PTD STEEL (FLOURO-CARB)	STAINLESS STEEL	WELDED CONST
FENCE COPINGS		.050			●
HOLD DOWN CLEATS	.050				
EDGE FASCIA / RIDGE FLASH		.050			●
COUNTER FLASHING	.032	.032			
EAVE DRIP		.032			
METAL CLADDING		.032			
J TRIM		.040			
COL TOP FLASHING		.040			

FLASHING & SHEET METAL NOTES

1. IN GENERAL, FLASHINGS VISIBLE FROM THE GROUND ARE TO BE MADE FROM ALUMINUM WITH A 20-YEAR FLUROCARBON COATING.
2. FLASHING NOT VISIBLE FROM THE GROUND MAY BE MADE FROM MILL FINISHED ALUMINUM.
3. FLASHINGS WITH A PAINT COATING & REQUIRING WELDING WILL BE TOUCHED UP WITH THE MANUFACTURERS TOUCH UP PAINT. THE WELDED CONSTRUCTION HAS PRIORITY OVER THE 20 YEAR WARRANTY. COORDINATE WITH DETAILS FOR WELDED CONSTRUCTION.
4. VENTS, JACKS AND OTHER RTE ON SHINGLE ROOF SHALL BE PAINTED BLACK.



A3 DETAIL
SCALE: 1 1/2" - 1'-Ø"



B3 DETAIL
NOT TO SCALE



C3 DETAIL
SCALE: 1 1/2" - 1'-Ø"



A2 DETAIL
SCALE: 3/4" = 1'-Ø"



B2 DETAIL
SCALE: 1 1/2" - 1'-Ø"



C2 DETAIL
SCALE: 1 1/2" - 1'-Ø"



A1 DETAIL
NOT TO SCALE
ROOF INSULATION PROFILE



B1 DETAIL
NOT TO SCALE



C1 DETAIL
SCALE: 1 1/2" - 1'-Ø"



ROOF PLAN
SCALE: 1/8"=1'-Ø"

ROOFING NOTES

1. SEE ROOF SPECIFICATIONS ON SHEET A Ø0.2.
2. TAPERED INSULATION FORMING CRICKETS DIRECTING WATER TO DRAINS, GUTTERS AND AWAY FROM EQUIPMENT SHALL HAVE A SLOPE OF ¼" : 12" UON.
3. COPINGS, EDGE FASCIAS AND RIDGE FLASHING SHALL HAVE CONTINUOUS HOLD DOWN CLIPS, UON. HOLD DOWN CLIPS SHALL BE A MIN OF Ø.Ø5Ø THICK.
4. WOOD FRAMING AND BLOCKING SHOWN ON THE ROOF DRAWINGS SHALL BE "TREATED REGARDLESS IF NOTED OR NOT.
5. ALL WOOD CURBS AND PERIMETER BLOCKING SHALL BE BOLTED TO THE ROOF STRUCTURE AT A MINIMUM OF 4'-Ø" ON CENTER. PROVIDE WOOD BLOCKING AS REQUIRED TO SECURE THE CURBS.
6. SUPPLY ALL RUNNING METAL TRIM WITH WELDED TERMINATIONS FLANGES AT THE END OF ALL RUNS. RUNNING SEAMS SHALL HAVE BACK-UP JOINING PLATES IN A COLOR TO MATCH THE COLOR OF THE ITEM BEING JOINED, UON.

ROOF LEGEND

RD ○	ROOF DRAIN DET B3/A2.Ø2	▨	RELIEF / INTAKE VENT SEE DET C3/A2.Ø2
▦	SOLAR POWERED ATTIC EXHAUST FAN	◎	CONCENTRIC VENT SEE DET C1/A6.Ø1
▩	MEMBRANE ROOF SEE ROOF NOTES	⊠	DRYER EXHAUST SEE DETAIL C2/A2.Ø2
◐	VTR SEE DETAIL B2/A2.Ø2	⊗	WATER HEATER I/O SEE DETAIL B1/A2.Ø2



ATTIC PLAN
SCALE: 1/8"=1'-Ø"

HUDSON+ASSOCIATES
ARCHITECTS
120 WEST QUEENS WAY SUITE 201 HAMPTON, VA.
(757) 722-1964 23669

BROGDEN LANE
ICF / MR HOME
FOR HNN CSB

SEPTEMBER Ø3, 2Ø08

COMMONWEALTH OF VIRGINIA
C. CRAIG HUDSON
No. 3768
Ø9-Ø3-Ø8
ARCHITECT

ROOF AND ATTIC PLAN

JOB NUMBER 0704

A2.02